

**TRWA RECOMMENDED 5/8" X 3/4" METER EQUIVALENTS
BASED ON AWWA SPECIFICATIONS AND DESIGN CRITERIA**

METER SIZE	RECOMMENDED CONTINUOUS RATE OF FLOW	RESIDENTIAL METER EQUIVALENTS
5/8" X 3/4"	10.0 GPM	1.00
3/4"	15.0 GPM	1.50
1"	25.0 GPM	2.50
1 1/2"	50.0 GPM	5.00
2"	80.0 GPM	8.00
3" DISP.	90.0 GPM	9.00
3" CMPD	160.0 GPM	16.00
3" TURB.	175.0 GPM	17.50
4" CMPD	250.0 GPM	25.00
4" TURB.	300.0 GPM	30.00
6" CMPD	500.0 GPM	50.00
6" TURB.	625.0 GPM	62.50
8" CMPD	800.0 GPM	80.00
10" CMPD	1,150.0 GPM	115.00

NOTE: ALTHOUGH AWWA DOES NOT RECOMMEND A CONTINUOUS FLOW OF GREATER THAN 50 PERCENT FOR DISPLACEMENT AND MULTIJET METERS, METER EQUIVALENTS ARE CALCULATED ON A PROPORTIONAL BASIS AND REMAIN THE SAME REGARDLESS OF ALLOWABLE RATES.